

**BOARD OF
BUILDING AND SAFETY
COMMISSIONERS**

MARSHA L. BROWN
PRESIDENT

PEDRO BIRBA
VICE-PRESIDENT

VAN AMBATIELOS
HELENA JUBANY
ELENORE A. WILLIAMS

**CITY OF LOS ANGELES
CALIFORNIA**



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

American Polymer Corp.
9176 So. 300 West, Suite 4
Sandy, Utah 84070

RESEARCH REPORT: RR 25142-T
(CSI 09960)

Attn: Michael Macris
(801) 255-9505

Expires: April 1, 2009

GENERAL APPROVAL - Renewal - American Polymer Anti-Graffiti GSS Color Coat and GSS Clear Coat as a non-sacrificial anti-graffiti Coating.

DETAILS

CSS Color Coat and GSS Clear Coat anti-graffiti coatings are two component epoxy paints. Both are classified as non-sacrificial coatings and may be applied to concrete block, masonry concrete, plaster, drywall, metal or wood. They may be applied on painted and unpainted surfaces.

The Approval is subject to the following conditions:

1. Anti-Graffiti coating must have the capability of having all types of paints and graffiti materials completely removed without damaging the uncoated surfaces to which they are applied.
2. The anti-graffiti coating and products required to remove graffiti from the coating must be non-toxic and comply with all applicable requirements of the South Coast Air Quality Management District.
3. The coating must be weather and rain resistant, abrasive resistant, peel resistant, ultra-violet resistant, non-yellowing and allow moisture vapor transmission as tested in accordance with applicable ASTM Standards.
4. The removal of graffiti shall cause little or no change in the appearance of the treated surface.

RR 25142-T
Page 1 of 2

American Polymer Corp.
RE: American Polymer Anti-Graffiti
GSS Color Coat & GSS Clear Coat


5. Disposal of graffiti removal by-products must conform to all state and city waste disposal regulations.
6. Manufacturer shall provide a copy of instructions for application of the coating, material specifications, and method and materials required to remove graffiti for each job site.
7. GSS Clear Coat is limited to uses on commercial buildings only. GSS Color Coat may be used on commercial and residential buildings.

DISCUSSION

This approval is subject to the satisfactory performance of these two coatings based on field tests covering the above conditions. The notarized statement from the manufacturer certifying that the product complies with Conditions No. 1 thru 5 of this approval is on file with the Research Division. This report is approved on a temporary basis until more specific requirements are established.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.



YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

UC
YC:elcm
RR25142/wp8.0
R05/30/07
4D6/6D6/6306